



DEVELOPMENT SERVICES CENTER
PUBLIC WORKS DEPARTMENT
17575 PEAK AVENUE
MORGAN HILL, CA 95037-5301
ENGINEERING: 408-778-6480
FAX: 408-779-7236
WWW.MORGANHILL.CA.GOV

ADDENDUM NO. 2

DATE: FEBRUARY 12, 2016
TO: ALL PLAN HOLDERS OF THE:
OAK CANYON BOOSTER STATION REHABILITATION
PROJECT
FROM: DAVID GITTLESON – CITY OF MORGAN HILL *Use for D6.*
SUBJECT: ADDITIONS/CHANGES

UNDER "CONTRACT"

REPLACE:

5. Time for Completion. Contractor will fully complete the Work for the Project within 180 calendar days from the commencement date given in the Notice to Proceed ("Contract Time"). By signing below, Contractor expressly waives any claim for delayed early completion.

WITH:

5. Time for Completion. Contractor will fully complete the Work for the Project within **220** calendar days from the commencement date given in the Notice to Proceed ("Contract Time"). By signing below, Contractor expressly waives any claim for delayed early completion.

UNDER TECHNICAL SPECIFICATIONS

IN SECTION 11320, VERTICAL TURBINE PUMPS, REPLACE:

<u>Characteristic</u>	<u>Value</u>
Minimum Column Diameter, in	10

WITH:

<u>Characteristic</u>	<u>Value</u>
Minimum Column Diameter, in	4

(all other values in table remain unchanged)

UNDER DRAWINGS

ON SHEET M002, DETAILS E AND F, REPLACE CALLOUT:

PIPE PENETRATION DET B/M003

WITH:

PIPE PENETRATION DET I/M003


ON SHEET M100, REPLACE CALLOUT:

PIPE SUPPORT (TYP) DET D/M001

WITH:

PIPE SUPPORT (TYP) DET B/M001

ON SHEET C102, ADD BURIED GATE VALVE AS SHOWN:



ADDENDUM ACKNOWLEDGMENT

Bidder acknowledges receipt of this addendum, which shall be attached to the proposal.

Contractor's Representative

Date

THIS DOCUMENT AND THE ATTACHMENTS SHALL BECOME PART OF THE PROJECTS SPECIFICATION

No attachments