



Addendum No. 3

DATE: OCTOBER 8, 2019

**TO: ALL PLANHOLDERS OF THE CENTENNIAL RECREATION CENTER
GENERATOR PROJECT**

FROM: YAT CHO – PROJECT ENGINEER *Yat Cho*

RE: CLARIFICATION

Page(s) 1.

1. On Sheet E1.1, Note 12 – Remove wording – “Fence Installed by others.” Fence shall be installed as part of this project.
2. For new feeders going to the existing Automatic Transfer Switch (ATS) reference Sheet E2.2 and 1/E1.1, a 3.5” conduit with 4 #350kcmil and 1 #4 ground are to be installed from the generator the ATS.
3. The existing Automatic Transfer Switch is to be used as part of this project.

ADDENDUM ACKNOWLEDGMENT

Bidder acknowledges receipt of this addendum, which shall be attached to the proposal.

Contractor's Representative

Date

THIS DOCUMENT SHALL BECOME A PART OF THE PROJECT SPECIFICATIONS