



Addendum No. 1

DATE: SEPTEMBER 23, 2019

**TO: ALL PLANHOLDERS OF THE CENTENNIAL RECREATION CENTER
GENERATOR PROJECT**

FROM: YAT CHO – PROJECT ENGINEER 

RE: CLARIFICATION

Page(s) 1.

1. Sheet E3.1, Add to Section 16620 – Standby Power Generator System – Part 2 – PRODUCTS:

H. Standby Power Generator shall be Generac SD400 12.5L, 400kW, 48 hours, 1,325 gallons Industrial Diesel Generator Set with a NEMA 1 rated enclosure or an approved equal.

ADDENDUM ACKNOWLEDGMENT

Bidder acknowledges receipt of this addendum, which shall be attached to the proposal.

Contractor's Representative

Date

THIS DOCUMENT SHALL BECOME A PART OF THE PROJECT SPECIFICATIONS